

CERTIFICATE

EC TYPE-EXAMINATION
acc. to Pressure Equipment Directive 97/23/EC

Certificate No.: IT01/1424/10

Name and address of
manufacturer:


CRYOGIAM s.r.l.
C/da Calderaro

I-93100 CALTANISSETTA (CL)

This is to confirm that a representative sample of the type range described below meets the requirements of the Pressure Equipment Directive 97/23/EC.

Examined acc. to Directive 97/23/EC:	EC type-examination (module B)
Test Report No.:	IT05/1423/10 (design) and IT01/1424/10 (manufacture)
Description of sample:	Centrale frigorifera a singolo circuito BT mod. BT 3XS15-56Y Central refrigeration unit with single BT circuit mod. 3XS15-56Y Serial No. 1521/10
Category::	III
Sample is representative for:	Assemblaggio e installazione de centrali di refrigerazione fabbricate con componenti conformi alla direttiva 97/23/CE, non superiori alla categoria III, valvole di sicurezza escluse. Le unità utilizzano soltanto fluidi frigoriferi del gruppo 2, diametro massimo delle tubazioni è 76 mm. // Assembly and installation of central refrigeration units manufactured with components conform to Directive 97/23/EC with maximum category III. Units use group 2 fluids only, the maximum piping diameter is 76 mm.
Drawing No.:	1521/10-A2
	Approved drawings are attached.
Remarks / Expiration date:	(1) Design code applied: UNI EN 14276-2:2006, (2) The validity of this type examination is directly coupled to six month periodically performed surveillance based on 97/23/EC Module C1, conducted by Notified Body 0090. (3) The type examination expires on MAR 12, 2021 based on fulfillment of the above mentioned condition, otherwise the validity expires automatically.

Jena, MAR 13, 2011



(U. Sprengholz)
Certification Body for Pressure Equipment of
TÜV Thüringen e.V.
Notified Body 0090 97/23/EC